



CERTIFICATE OF ANALYSIS

REPORTED TO Grand Forks, City of

PO Box 220

You know that the sample you collected after

snowshoeing to site, digging 5 meters, and

racing to get it on a plane so you can submit it

to the lab for time sensitive results needed to

make important and expensive decisions

(whew) is VERY important. We know that too.

GRAND FORKS, BC V0H 1H0

ATTENTION Dean Chapman **WORK ORDER** 8082564

PO NUMBER

2018-08-28 11:15 / 13°C **RECEIVED / TEMP** REPORTED 2018-08-30 17:23 **PROJECT Drinking Water**

40837.5581 **PROJECT INFO COC NUMBER**

Introduction:

CARO Analytical Services is a testing laboratory full of smart, engaged scientists driven to make the world a safer and healthier place. Through our clients' projects we become an essential element for a better world. We employ methods conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts. CARO is accredited by the Canadian Association for Laboratories Accreditation (CALA) to ISO 17025:2005 for specific tests listed in the scope of accreditation approved by CALA.

Big Picture Sidekicks

We've Got Chemistry

opportunities to support you.

It's simple. We figure the more you enjoy with fun and working our engaged team the more members; likely you are to give us continued Ahead of the Curve

Through research, regulation knowledge, and instrumentation, are your analytical centre the technical knowledge you BEFORE you need it, so you can stay up to date and in the know.

If you have any questions or concerns, please contact me at estclair@caro.ca

Authorized By:

Eilish St.Clair, B.Sc., C.I.T. Client Service Representative

1-888-311-8846 | www.caro.ca



TEST RESULTS

REPORTED TO PROJECT	Grand Forks, City of Drinking Water				WORK ORDER REPORTED	8082564 2018-08-3	30 17:23
Analyte		Result	Guideline	RL	Units	Analyzed	Qualifier
East Zone Reser	voir (8082564-01) Matrix:	Water Sample	d: 2018-08-27 10:05				
Microbiological Pa	rameters						
Coliforms, Total		< 1	MAC = 0	1	CFU/100 mL	2018-08-28	
E. coli		< 1	MAC = 0	1	CFU/100 mL	2018-08-28	
Valley Heights B	ooster Station (8082564-02	?) Matrix: Wate	r Sampled: 2018-08	3-27 10:30			
Microbiological Pa	rameters						
Coliforms, Total		< 1	MAC = 0	1	CFU/100 mL	2018-08-28	
E. coli		< 1	MAC = 0	1	CFU/100 mL	2018-08-28	
Well #3 (8082564	-03) Matrix: Water Samp	oled: 2018-08-27	08:05				
Microbiological Pa	rameters						
Coliforms, Total		< 1	MAC = 0	1	CFU/100 mL	2018-08-28	
E. coli		< 1	MAC = 0	1	CFU/100 mL	2018-08-28	
J.D. Park (808250	64-04) Matrix: Water San	npled: 2018-08-2	27 09:10				
Microbiological Pa	rameters						
Coliforms, Total		< 1	MAC = 0	1	CFU/100 mL	2018-08-28	
E. coli		< 1	MAC = 0	1	CFU/100 mL	2018-08-28	



APPENDIX 1: SUPPORTING INFORMATION

REPORTED TO Grand Forks, City of **PROJECT** Drinking Water

WORK ORDER

8082564

REPORTED 2018-08-30 17:23

Analysis Description	Method Ref.	Technique	Location
Coliforms, Total in Water	SM 9222* (2006)	Membrane Filtration / Chromocult Agar	Kelowna
E. coli in Water	SM 9222* (2006)	Membrane Filtration / Chromocult Agar	Kelowna

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

Glossary of Terms:

RL Reporting Limit (default)

Less than the specified Reporting Limit (RL) - the actual RL may be higher than the default RL due to various factors

CFU/100 mL Colony Forming Units per 100 millilitres

MAC Maximum Acceptable Concentration (health based)

SM Standard Methods for the Examination of Water and Wastewater, American Public Health Association

General Comments:

The results in this report apply to the samples analyzed in accordance with the Chain of Custody document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing. The quality control (QC) data is available upon request