

### **CERTIFICATE OF ANALYSIS**

| REPORTED TO                          | Grand Forks, City of<br>PO Box 220<br>GRAND FORKS, BC V0H 1H0 |   |  |
|--------------------------------------|---|---|--|
| ATTENTION                            | Dean Chapman  | WORK ORDER                                | 8061012  |
| PO NUMBER<br>PROJECT<br>PROJECT INFO | Drinking Water  | RECEIVED / TEMP<br>REPORTED<br>COC NUMBER | 2018-06-12 10:30 / 7°C<br>2018-06-13 17:30<br>40837.5581 |

#### Introduction:

CARO Analytical Services is a testing laboratory full of smart, engaged scientists driven to make the world a safer and healthier place. Through our clients' projects we become an essential element for a better world. We employ methods conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts. CARO is accredited by the Canadian Association for Laboratories Accreditation (CALA) to ISO 17025:2005 for specific tests listed in the scope of accreditation approved by CALA.

We've Got Chemistry

### Big Picture Sidekicks



You know that the sample you collected after snowshoeing to site, digging 5 meters, and racing to get it on a plane so you can submit it to the lab for time sensitive results needed to make important and expensive decisions (whew) is VERY important. We know that too. It's simple. We figure the more you enjoy working with our fun and engaged team members; the more likely you are to give us continued opportunities to support you.

👗 A

Ahead of the Curve

Through research, regulation knowledge, and instrumentation, we are your analytical centre the for technical knowledge you need, BEFORE you need it, so you can stay up to date and in the know.

If you have any questions or concerns, please contact me at estclair@caro.ca

Authorized By:

Eilish St.Clair, B.Sc., C.I.T. Client Service Representative

1-888-311-8846 | www.caro.ca

#110 4011 Viking Way Richmond, BC V6V 2K9 | #102 3677 Highway 97N Kelowna, BC V1X 5C3 | 17225 109 Avenue Edmonton, AB T5S 1H7

Caring About Results, Obviously.



# **TEST RESULTS**

| REPORTED TO<br>PROJECT   | Grand Forks, City of<br>Drinking Water  |                               |                             |    | WORK ORDER<br>REPORTED | 8061012<br>2018-06-1 | 3 17:30  |
|--|---|-------------------------------|-----------------------------|----|------------------------|----------------------|----------|
| Analyte  |   | Result                        | Guideline                   | RL | Units                  | Analyzed             | Qualifie |
| East Zone Reser  | voir (8061012-01)   Matrix:             | Water   Sample                | d: 2018-06-11 10:50         |    |                        |                      |          |
| Microbiological Pa   | rameters                                |                               |                             |    |                        |                      |          |
| Coliforms, Total   |   | < 1                           | MAC = 0                     | 1  | CFU/100 mL             | 2018-06-12           |          |
| E. coli  |   | < 1                           | MAC = 0                     | 1  | CFU/100 mL             | 2018-06-12           |          |
| <i>Microbiological Pa</i><br>Coliforms, Total  | rameters                                | < 1                           | MAC = 0                     | 1  | CFU/100 mL             | 2018-06-12           |          |
| •  |   | - 1                           | MAC = 0                     | 1  | CELI/100 ml            | 2018 06 12           |          |
|  |   |                               | MAC = 0                     |    | CFU/100 mL             | 0040 00 40           |          |
| E. coli  |   | < 1                           | MAC = 0                     | 1  |                        | 2018-06-12           |          |
|  | -03)   Matrix: Water   Samp<br>rameters |                               |                             | 1  |                        | 2018-06-12           |          |
| Well #2 (8061012   |   |                               |                             |    | CFU/100 mL             | 2018-06-12           |          |
| Well #2 (8061012<br>Microbiological Pa   |   | led: 2018-06-11               | 10:30                       | 1  |                        |                      |          |
| Well #2 (8061012<br>Microbiological Pa<br>Coliforms, Total<br>E. coli                    | rameters<br>ry (8061012-04)   Matrix: W | led: 2018-06-11<br>< 1<br>< 1 | 10:30<br>MAC = 0<br>MAC = 0 | 1  | CFU/100 mL             | 2018-06-12           |          |
| Well #2 (8061012<br>Microbiological Pa<br>Coliforms, Total<br>E. coli<br>Hutton Elementa | rameters<br>ry (8061012-04)   Matrix: W | led: 2018-06-11<br>< 1<br>< 1 | 10:30<br>MAC = 0<br>MAC = 0 | 1  | CFU/100 mL             | 2018-06-12           |          |



## **APPENDIX 1: SUPPORTING INFORMATION**

| REPORTED TO<br>PROJECT                   | Grand Fo<br>Drinking V | rks, City of<br>Vater           |  | WORK ORDER<br>REPORTED | 8061012<br>2018-06-13 17:30 |
|--|------------------------|---------------------------------|--|------------------------|-----------------------------|
| Analysis Descr                           | iption                 | Method Ref.                     | Technique                                  |                        | Location                    |
| Coliforms, Total in                      | Water                  | SM 9222* (2006)                 | Membrane Filtration / Chromocult Ag        | jar                    | Kelowna                     |
| E. coli in Water                         |                        | SM 9222* (2006)                 | Membrane Filtration / Chromocult Ag        | jar                    | Kelowna                     |
| Note: An asterisk in<br>Glossary of Term |                        | Reference indicates that the C, | ARO method has been modified from the refe | erence method          |                             |

| RL         | Reporting Limit (default)   |
|------------|---|
| <          | Less than the specified Reporting Limit (RL) - the actual RL may be higher than the default RL due to various factors |
| CFU/100 mL | Colony Forming Units per 100 millilitres  |
| MAC        | Maximum Acceptable Concentration (health based)   |
| SM         | Standard Methods for the Examination of Water and Wastewater, American Public Health Association                      |

### **General Comments:**

The results in this report apply to the samples analyzed in accordance with the Chain of Custody document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing. The quality control (QC) data is available upon request