

<b>REPORTED TO</b>	Grand Forks, City of PO Box 220 GRAND FORKS, BC V0H 1H0	<b>TEL</b>	(250) 442-2434
		<b>FAX</b>	(250) 442-8263
<b>ATTENTION</b>	Dean Chapman	<b>WORK ORDER</b>	5050752
<b>PO NUMBER</b>		<b>RECEIVED / TEMP</b>	May-12-15 11:15 / 14°C
<b>PROJECT</b>	Drinking Water	<b>REPORTED</b>	May-15-15
<b>PROJECT INFO</b>		<b>COC NUMBER</b>	40837.5581

**General Comments:**

CARO Analytical Services employs methods which are conducted according to procedures accepted by appropriate regulatory agencies, and/or are conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts, except where otherwise agreed to by the client.

The results in this report apply to the samples analyzed in accordance with the Chain of Custody or Sample Requisition document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing.



Authorized By: **Ed Hoppe, B.Sc., P.Chem.**  
Division Manager, Kelowna

**Please contact CARO if more information is needed or to provide feedback on our services.**

**Locations:**

#110 4011 Viking Way  
Richmond, BC V6V 2K9  
Tel: 604-279-1499 Fax: 604-279-1599

#102 3677 Highway 97N  
Kelowna, BC V1X 5C3  
Tel: 250-765-9646 Fax: 250-765-3893

17225 109 Avenue  
Edmonton, AB T5S 1H7  
Tel: 780-489-9100 Fax: 780-489-9700

[www.caro.ca](http://www.caro.ca)

**REPORTED TO PROJECT** Grand Forks, City of  
Drinking Water

**WORK ORDER REPORTED** 5050752  
May-15-15

Analysis Description	Method Reference	Technique	Location
E. coli (CCA)	APHA 9222*	Membrane Filtration / Chromocult Agar	Kelowna
Total Coliforms (CCA)	APHA 9222*	Membrane Filtration / Chromocult Agar	Kelowna

*Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method*

**Method Reference Descriptions:**

APHA Standard Methods for the Examination of Water and Wastewater, 22nd Edition, American Public Health Association/American Water Works Association/Water Environment Federation

**Glossary of Terms:**

MRL Method Reporting Limit  
 < Less than the Reported Detection Limit (RDL) - the RDL may be higher than the MRL due to various factors such as dilutions, limited sample volume, high moisture, or interferences  
 AO Aesthetic objective  
 MAC Maximum acceptable concentration (health based)  
 OG Operational guideline (treated water)  
 CFU/100 mL Colony Forming Units per 100 millilitres

**Standards / Guidelines Referenced in this Report:**

Guidelines for Canadian Drinking Water Quality (Oct 2014)

Website: [http://www.hc-sc.gc.ca/ewh-semt/alt\\_formats/pdf/pubs/water-eau/sum\\_guide-res\\_recom/sum\\_guide-res\\_recom-eng.pdf](http://www.hc-sc.gc.ca/ewh-semt/alt_formats/pdf/pubs/water-eau/sum_guide-res_recom/sum_guide-res_recom-eng.pdf)

*Note: In some cases, the values displayed on the report represent the lowest guideline and are to be verified by the end user*

**REPORTED TO PROJECT** Grand Forks, City of  
Drinking Water

**WORK ORDER REPORTED** 5050752  
May-15-15

Analyte	Result / Recovery	Standard / Guideline	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------	-------	----------	----------	-------

**Sample ID: East Zone Reservoir (5050752-01) [Water] Sampled: May-11-15 08:55**

**Microbiological Parameters**

Coliforms, Total	< 1	MAC = None Detected	1	CFU/100 mL	May-12-15	May-13-15	
E. coli	< 1	MAC = None Detected	1	CFU/100 mL	May-12-15	May-13-15	

**Sample ID: Valley Heights Booster Stn (5050752-02) [Water] Sampled: May-11-15 10:00**

**Microbiological Parameters**

Coliforms, Total	< 1	MAC = None Detected	1	CFU/100 mL	May-12-15	May-13-15	
E. coli	< 1	MAC = None Detected	1	CFU/100 mL	May-12-15	May-13-15	

**Sample ID: Boundary Hospital (5050752-03) [Water] Sampled: May-11-15 08:10**

**Microbiological Parameters**

Coliforms, Total	< 1	MAC = None Detected	1	CFU/100 mL	May-12-15	May-13-15	
E. coli	< 1	MAC = None Detected	1	CFU/100 mL	May-12-15	May-13-15	

**Sample ID: Well #3 (5050752-04) [Water] Sampled: May-11-15 07:55**

**Microbiological Parameters**

Coliforms, Total	< 1	MAC = None Detected	1	CFU/100 mL	May-12-15	May-13-15	
E. coli	< 1	MAC = None Detected	1	CFU/100 mL	May-12-15	May-13-15	