

REPORTED TO	Grand Forks, City of PO Box 220 GRAND FORKS, BC V0H 1H0	TEL	(250) 442-8266
		FAX	(250) 442-8263
ATTENTION	Dean Chapman	WORK ORDER	7110588
PO NUMBER		RECEIVED / TEMP	2017-11-07 09:00 / 5°C
PROJECT	Drinking Water	REPORTED	2017-11-08
PROJECT INFO		COC NUMBER	40837.5581

General Comments:

CARO Analytical Services employs methods which are conducted according to procedures accepted by appropriate regulatory agencies, and/or are conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts, except where otherwise agreed to by the client.

The results in this report apply to the samples analyzed in accordance with the Chain of Custody or Sample Requisition document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing.



Authorized By: **Kristin McKeown**
Account Manager

If you have any questions or concerns, please contact me at kmckeown@caro.ca

Locations:

#110 4011 Viking Way
Richmond, BC V6V 2K9
Tel: 604-279-1499

#102 3677 Highway 97N
Kelowna, BC V1X 5C3
Tel: 250-765-9646

17225 109 Avenue
Edmonton, AB T5S 1H7
Tel: 780-489-9100

www.caro.ca

REPORTED TO PROJECT Grand Forks, City of
Drinking Water

WORK ORDER REPORTED 7110588
2017-11-08

Analysis Description	Method Reference	Technique	Location
Coliforms, Total in Water	SM 9222* (2006)	Membrane Filtration / Chromocult Agar	Kelowna
E. coli in Water	SM 9222* (2006)	Membrane Filtration / Chromocult Agar	Kelowna

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

Method Reference Descriptions:

SM Standard Methods for the Examination of Water and Wastewater, American Public Health Association/American Water Works Association/Water Environment Federation

Glossary of Terms:

MRL Method Reporting Limit
 < Less than the Reported Detection Limit (RDL) - the RDL may be higher than the MRL due to various factors such as dilutions, limited sample volume, high moisture, or interferences
 AO Aesthetic objective
 MAC Maximum acceptable concentration (health based)
 OG Operational guideline (treated water)
 CFU/100 mL Colony Forming Units per 100 millilitres
 MAC = 0 Maximum Acceptable Concentration (health based)

Standards / Guidelines Referenced in this Report:

Guidelines for Canadian Drinking Water Quality (Health Canada, Feb 2017)

Website: http://www.hc-sc.gc.ca/ewh-semt/alt_formats/pdf/pubs/water-eau/sum_guide-res_recom/sum_guide-res_recom-eng.pdf

Note: In some cases, the values displayed on the report represent the lowest guideline and are to be verified by the end user

REPORTED TO PROJECT Grand Forks, City of
Drinking Water

WORK ORDER REPORTED 7110588
2017-11-08

Analyte	Result / Recovery	Standard / Guideline	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------	-------	----------	----------	-------

Sample ID: East Zone Reservoir (7110588-01) [Water] Sampled: 2017-11-06 13:22

Microbiological Parameters

Coliforms, Total	< 1	MAC = 0	1	CFU/100 mL	N/A	2017-11-07	
E. coli	< 1	MAC = 0	1	CFU/100 mL	N/A	2017-11-07	

Sample ID: Valley Heights Booster Station (7110588-02) [Water] Sampled: 2017-11-06 13:45

Microbiological Parameters

Coliforms, Total	< 1	MAC = 0	1	CFU/100 mL	N/A	2017-11-07	
E. coli	< 1	MAC = 0	1	CFU/100 mL	N/A	2017-11-07	

Sample ID: Super Save Gas (7110588-03) [Water] Sampled: 2017-11-06 12:40

Microbiological Parameters

Coliforms, Total	< 1	MAC = 0	1	CFU/100 mL	N/A	2017-11-07	
E. coli	< 1	MAC = 0	1	CFU/100 mL	N/A	2017-11-07	

Sample ID: Evergreen Cemetary (7110588-04) [Water] Sampled: 2017-11-06 13:00

Microbiological Parameters

Coliforms, Total	< 1	MAC = 0	1	CFU/100 mL	N/A	2017-11-07	
E. coli	< 1	MAC = 0	1	CFU/100 mL	N/A	2017-11-07	